


Poepping, Stone, Bach & Associates, Inc.

Engineers, Architects, Surveyors, GIS

FRACTURE CRITICAL INSPECTION REPORT **BRIDGE 2740017 MILLER COUNTY, MISSOURI**

SWINGING BRIDGE ROAD OVER GRAND AUGLAIZE



Prepared for the Missouri Department of Transportation and **Miller County Commission**

September 17, 2018



3523 MAIN STREET P.O. BOX 817 • KEOKUK, IA 52632 ☐ 801 BROADWAY SUITE 248 P.O. BOX 190 • HANNIBAL, MO 63401 PHONE 217/223-4605
 FAX 217/223-1546

PHONE 319/524-8730
 FAX 217/223-1546

PHONE 573/406-0541
 FAX 217/223-1546

EXECUTIVE SUMMARY

Poepping, Stone, Bach & Associates, Inc., performed a comprehensive fracture critical inspection on the 500 foot long suspension bridge, inventoried as MoDOT structure number 2740017, on Swinging Bridge Road over Grand Auglaize, in Miller County, Missouri. The inspection was conducted during the period August 7-9, 2018, by Pat Martens (team leader) and Skip Wilson. The bridge is owned by Miller County.

The bridge was built in 1920, and is a two-span suspension type bridge. The bridge has a wooden plank deck with a 20 foot roadway width. Timber running boards dictate (along with load posting) that only one-lane traffic can accommodate the spans to cross the bridge. An average daily traffic count is estimated at 250 vehicles per day.

The bridge is posted for a 3 ton load limit.

Results of the inspection indicate the superstructure is in poor condition (item 59 = 4), due to numerous broken strands within the main suspension cable units, and worn and broken strands within various hanger cable assemblies. Overall, the superstructure elements are mainly showing minor to moderate surface rust throughout, along with minor pitting. Many hanger cables are loose, and various assemblies have slid along the main suspension cable.

Specific details with regard to each individual fracture critical member can be found in the attached Fracture Critical Inspection Report spreadsheet. This includes the size and corresponding configuration of the components that make up each fracture critical member.

Based on the information gathered during this inspection, there is still continued deterioration that will limit the life of the structure. Without additional repairs to various hanger assemblies, the estimated expected life is projected at five years for vehicular traffic. Due to the historic nature of the structure, there may be an interest in continuing service on the bridge for pedestrian access only after the useful life is exhausted.

The recommended fracture critical inspection frequency is 24 months.


Following are fracture critical inspection procedures and general findings from the inspection.

Fracture Critical Inspection Identification and Procedures


The structure orientation is east to west, with span one being an approach span of 85' 11", and span two serving as the main span of 414' 1". The fracture critical members are identified as main suspension cables (U), hanger cables (H), and floor beams (FB).

Main suspension cables are a pair of bundled steel strands of unknown quantity, with a soft wire wrap. These main cables are identified as north and south cables (U), and differentiated into segments between individual hangers that are numbered from U1 through U82, for documentation purposes. The end sections of the main cables to the anchor blocks at each bridge end are labeled U0 and U83. The end segments are numbered U0-U1 and U82-U83.

Hanger cables (H) are vertical tension members that stretch from the upper cable (U) to the floor beam (FB), with each hanger identified as either corresponding to north or south.



Floor beams are rolled (8") S-beams that run transversely between each north and south main cable / hanger assembly, with a total of 82 floor beams in the bridge. The floor beams are spaced at 14' 2", and support a multi stringer system that runs parallel to the roadway, and carries loading from a timber deck. The stringer system is not part of the fracture critical evaluation.



The inspection is conducted utilizing visual observation from the deck level or on ladders extended up from the deck, under live traffic (no traffic control). Disruption of the inspection process can occur as cars occasionally access the bridge. Ground level inspection is made from under span 1 and the most easterly parts of span 2, up to the waterway, utilizing ladders or

camera inspection (Go Pro on extendable pole). All aspects of the inspection are performed through visual observation from deck level, free climbing (of towers), and access with extension ladders. Cleaning of vines from the main suspension cables may be necessary, especially in the vicinity of the west tower, and between the towers and anchor blocks, in order to adequately view the members. No special access or testing equipment is necessary unless conditions dictate further investigation.

Inspection of the main cables and hanger cables can be made by deck level viewing of the lower portions of the cables, and by use of ladders for the higher reaches of the cables. A minimum 32 foot extension ladder is needed for the highest peaks of the cables.

Floor beam inspection is done through visual means at the deck end, to view beam ends. The remainder of the floor beam is visible through the gaps in the timber deck. In particular, the lower portion of the beam is in tension due to bending and is the main area of focus of the fracture critical inspection. A Go Pro camera on an extendable pole can also be used for closer documentation, as necessary.


The towers are not part of the fracture critical inspection, but were generally inspected through free climbing, and the main cable saddles were inspected where they drape over the top of towers.

Steel stringers (not fracture critical) in the floor system are supported by the floor beams. The stringers were not inspected hands-on, but through a general cursory review from ground level and through the deck planking.

Inspection Results

Main Suspension Cables:


Each main cable is a larger cluster of steel wire strands (unknown quantity) with a soft wire wrap. The cables are suspended from two steel towers and then anchored into concrete blocks off of the bridge.



The strands are generally rusty in condition along the outer core, with no significant section loss. The outer strand layers that are exposed to the elements have areas of the strands that have minor pitting. Investigation of the various segments of the main cables, hands-on, reveal that there are varying degrees of loose strands evident around the outer core of the cable.

The bulk of the core though appears very solid. In certain areas individual strand breakage is evident. The exact number of strands fractured is difficult to ascertain, but for the most part, judging by the looseness of the strands, and assuming those strands are in fact failed somewhere in the main cable, there are as many as a dozen or more strands ruptured, or at least not functioning in tension.

At the far west end, in the segment between the anchor block and last hanger (H82), there is the largest concentration of broken and/or loose strands. The south main cable, approximately 10 feet from the



anchor, includes excess of 40 loose strands which are not bound by any wrapping. In close proximity to that grouping, about 24 strands are observed to be severed. At the anchor itself, the interface looks good, but there are about 12 broken strands noted. In the corresponding cable to the north,

approximately 20 feet from the anchor, there are about 15 observed broken strands. The area of draping over the towers looks good. This would be locations corresponding to U14U15 and also immediately to the west of U82. There are a few observed broken cables over the saddles at U82. Strands in the saddle at U14U15 have been spliced in the past.

Vertical Members (Hanger Cables):

There are 82 pairs of hanger cables that are oriented vertically from the main suspension cables and wrap around the ends of the floor beams. There are 10 wire twisted strands that form a cable and are looped

around the floor beam at each hanger location. Various hangers were observed to be loose and/or untwisted.

The hanger cables are generally rusting, and have minor to isolated areas of moderate pitting. The moderate pitting is most noticeable in the upper portions of various identified cables on the *Fracture Critical Inspection Spreadsheet*, with minor section loss. Where the bottom portion of the cables come into contact with the floor beams, wear is evident at the top flange location. This occurs in a vast majority of the floor beams, with varying degrees of section loss occurring in



strands. There are many more documented wire breaks since the last inspection. The Fracture Critical


Inspection spreadsheet captures the degree of wear/section loss and wire breakage for each individual hanger location.

Floor Beams:

All of the floor beams look to be in good condition with only general rusting and minor pitting. In addition, the rubbing action of the hanger cables on the top flange of the floor beam is causing minor wear in various locations. A longitudinal cable acts as bracing to tie the floor beam ends together.



Typical condition of floor beams.



Note: gouge in top flange of floor beam 1 at hanger cable.

This is one of the more extreme cases of gouging.

Towers:

The suspension towers are not fracture critical. They have general rusting and minor pitting. A cursory review of the towers indicates there are isolated areas of moderate to heavy section loss in plating, lattice and connection angles. The towers are for the most part plumb. There is also a missing anchor bolt in the base of tower 1.

Stringers:

Stringers, like the floor beams, are in good condition overall, with general rusting and minor pitting. One stringer was observed out of alignment.

Maintenance Recommendations:

Review Fracture Critical Inspection Spreadsheet and consider replacing or retrofitting those vertical hanger locations with observed wire breaks.

A complete set of photos taken during the inspection is included as an attachment to this report.

Missouri Department of Transportation Fracture Critical Inspection Report

Structure #: 2740017 Federal ID #: 20779

District: CD

County: Miller

Facility Carried: Swing Bridge Road Feature Intersected: Grand Auglaize

Location: S 36 T 39N R 15W

Year Built: 1920

Structure Status: P-Posted

Approved Posting: 3 Tons
Field Posting: 3 Tons

rieid rosting. 5 ions

Layout Description: East to West

Inspection Date: 8/9/2018

Inspection Frequency: 24 Months

Inspector: PSBA

Latitude: 38 D 4 M 37 S

Longitude: 92 D 31 M 36 S

PRIMARY SUPERSTRUCTURE MEMBERS

MEMBER

FRACTURE CRITICAL

DESCRIPTION

MAIN SUSPENSION

YES

Bundled Steel Strands (0.15" each)

VERTICAL (HANGER)

YES

10 twisted wire cable

FLOOR BEAM

YES

Rolled 8" I-Beam

STRINGERS

NO

Rolled 4" S-Beam + 4" Channel

BRIDGE Miller County Swinging Bridge Road

	Minor wear to top flange of floor beams due to rubbing of cables.	General
TYPICAL CONDITIONS:	rusting and minor pitting overall.	

FB#	
1	North side -gouged due to hanger.
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	

TYPICAL CONDITIONS:		Minor wear to top flange of floor beams due to rubbing of cables. General rusting and minor pitting overall.
CONDITIO	143.	rusting and militor pitting overall.
FB#		
13		
14		
15		
16		
17		
18		
19		
20		
21		
22		
23		
24		

TVDICAL		
TYPICAL CONDITIONS:		Minor wear to top flange of floor beams due to rubbing of cables. General rusting and minor pitting overall.
	7	
FB#		
25		
26		
27		
28		
20		
29		
30		
31		
32		
33		
34		
54		
35		
36		

TYPICAL	Minor wear to top flange of floor beams due to rubbing of cables. General
CONDITIONS:	rusting and minor pitting overall.

	٦
FB#	
37	Minor debris on lower flange
38	
39	
40	
10	
41	
41	
42	
43	
44	
45	
46	
27	
47	
48	

TYPICAL CONDITION	NS.	Minor wear to top flange of floor beams due to rubbing of cables. General rusting and minor pitting overall.
CONDINO		rading and minor pitting overalls
FB#		
49		
50		
51		
52		
53		
54		
55		
56		
57		
58		
59		
60		

TYPICAL	Minor wear to top flange of floor beams due to rubbing of cables. General
CONDITIO	
FB#	
C1	
61	
62	
63	
64	
- 07	
65	
66	
67	9
68	
69	
0.5	
70	
74	
71	
72	

TYPICAL	Minor wear to top flange of floor beams due to rubbing of cables. General
CONDITIO	
	1
FB#	
73	
74	
75	
7.5	e)
76	
77	
78	
78	
79	
80	
81	
82	Dirt, debris collected at lateral bracing connection.

BRIDGE 2740017 Miller County Swinging Bridge Road

TYPICAL

CONDITIONS:

UPPER	NORTH	SOUTH
UO		18 broken strands at anchor point. 5
(Anchor)-	2 broken strands at anchor. Wrap wire	broken strands at U1. Wrap wire broken,
U1	broken and loose.	loose.
U1-U2	4 broken/loose strands in outer core at U2.	
U2-U3		6 broken strands at U3.
U3-U4		3 broken strands at U4.
U4-U5		10 strands loose/broken in outer core.
U5-U6	4 broken/loose strands in outer core.	10 strands loose/broken in outer core.
U6-U7	4 broken/loose strands in outer core.	10 strands loose/broken in outer core.
U7-U8	4 broken/loose strands in outer core.	11 strands loose/broken in outer core.
U8-U9	5 broken/loose strands in outer core.	12 strands loose/broken in outer core.
U9-U10	6 broken/loose strands in outer core.	12 strands loose/broken in outer core.
U10-U11		12 strands loose/broken in outer core.
U11-U12		

BRIDGE 2740017 Miller County Swinging Bridge Road

TYPICAL	
CONDITIONS:	Rusting with minor areas of pitting in outer layer of strands.

UPPER	NORTH	SOUTH
UPPER	NONTH	3001h
U12-U13		
012-013		
1112 1114	3 broken/loose strands in outer core.	
013-014	5 brokery loose strands in outer core.	
	3 broken/loose strands in outer core.	
1111/1115	Tower in between. Saddle area looks good.	Towar in hetween Saddle area looks good
014-013	Tower in between. Saudie area looks good.	Tower in between. Saudie area looks good.
U15-U16		
013 010		
U16-U17		
U17-U18		
U18-U19		
U19-U20	6 loose strands in outer core (top).	
U20-U21		
	12 broken/loose strands in outer core	
U21-U22	(bottom).	
U22-U23	12 broken/loose strands in outer core.	12 broken strands (bottom) at U23.
U23-U24	12 broken/loose strands in outer core.	14 loose/hanging strands.

BRIDGE 2740017 Miller County Swinging Bridge Road

TYPICAL

CONDITIONS:

UPPER	NORTH	SOUTH
U24-U25	11 loose strands in outer core.	14 broken/loose strands in outer core.
U25-U26	11 loose strands in outer core.	14 broken/loose strands in outer core.
U26-U27	11 loose strands in outer core.	14 broken/loose strands in outer core.
U27-U28	11 loose strands in outer core.	14 broken/loose strands in outer core.
U28-U29	11 loose strands in outer core.	14 broken/loose strands in outer core.
U29-U30	11 loose strands in outer core.	
U30-U31	11 loose strands in outer core.	At U30, loose strands in main cable.
U31-U32	6 loose strands in outer core. 1 severed strand. At U31, loose strands have been secured to vertical.	3 loose strands in outer core + 3 broken strands.
U32-U33	6 loose strands in outer core.	3 loose strands in outer core + 2 broken strands.
U33-U34	4 loose stands in outer core.	3 loose strands in outer core.
	4 loose stands in outer core (bottom).	12 loose strands.
	4 loose stands in outer core (bottom).	12 loose strands.

BRIDGE 2740017 Miller County Swinging Bridge Road

TYPICAL

CONDITIONS:

UPPER	NORTH	SOUTH
U36-U37	4 loose strands in outer core (bottom).	6 loose strands in outer core (bottom).
U37-U38	4 loose strands in outer core (bottom).	6 loose strands in outer core (bottom).
U38-U39	4 loose strands in outer core.	6 loose strands in outer core.
U39-U40	4 loose strands in outer core.	6 loose strands in outer core. 2 strands reconnected.
U40-U41	4 loose strands in outer core.	6 loose strands in outer core.
U41-U42	4 loose strands in outer core.	6 loose strands in outer core.
U42-U43	5 loose strands in outer core.	6 loose strands in outer core.
U43-U44	5 loose strands in outer core.	4 loose strands in outer core. 1 broken strand.
U44-U45	4 loose strands in outer core.	4 loose strands in outer core.
U45-U46	4 loose strands in outer core.	5 loose strands in outer core.
U46-U47	3 loose strands in outer core.	3 loose strands in outer core.
U47-U48	3 loose strands in outer core.	3 loose strands in outer core.

BRIDGE 2740017 Miller County Swinging Bridge Road

TYPICAL

CONDITIONS:

UPPER	NORTH	SOUTH
OTTER	NORTH	300111
U48-U49	3 loose strands in outer core.	2 loose strands in outer core.
		3 land attended in outcomes 4 hooks
U49-U50	3 loose strands in outer core.	2 loose strands in outer core. 1 broken strand.
0.000		- Contract
U50-U51	4 loose strands in outer core.	3 loose strands in outer core.
U51-U52	4 loose strands in outer core.	3 loose strands in outer core.
	4 loose strands in outer core. 1 broken	3 loose strands in outer core. 1 broken
U52-U53	strand.	strand.
	4 loose strands in outer core. 1 broken	
U53-U54		3 loose strands in outer core.
1154 1155	7 loose strands in outer core.	6 loose strands in outer core.
034-033	7 loose strands in outer core.	6 loose strailus ili outer core.
U55-U56	7 loose strands in outer core.	6 loose strands in outer core.
1156-1157	5 loose strands in outer core.	3 loose strands in outer core.
030 037	3 loose straines in outer cove.	5 10050 Strainus III Guter Core.
U57-U58	5 loose strands in outer core.	3 loose strands in outer core.
U58-U59	3 loose strands in outer core.	2 loose strands in outer core.
U59-U60	3 loose strands in outer core.	3 loose strands in outer core.

BRIDGE 2740017 Miller County Swinging Bridge Road

TYPICAL

CONDITIONS:

UPPER	NORTH	SOUTH
	5 loose strands in outer core. 1 broken	
U60-61	strand.	3 loose strands in outer core.
U61-U62	4 loose strands in outer core.	3 loose strands in outer core.
	4 loose strands in outer core. 1 broken	3 loose strands in outer core. 1 broken
U62-U63	strand.	strand.
U63-U64	6 loose strands in outer core. 2 broken strands.	4 loose strands in outer core. 1 broken strand.
U64-U65	7 loose strands in outer core.	6 loose strands in outer core.
U65-U66	5 loose strands in outer core. 1 broken strand.	7 loose strands in outer core. 1 broken strand.
U66-U67	7 loose strands in outer core. 1 broken strand.	11 loose strands in outer core.
U67-U68	5 loose strands in outer core.	11 loose strands in outer core. 1 broken strand.
U68-U69	6 loose strands in outer core.	11 loose strands in outer core.
U69-U70	6 loose strands in outer core.	11 loose strands in outer core.
U70-U71	7 loose strands in outer core.	11 loose strands in outer core.
U71-U72	6 loose strands in outer core.	11 loose strands in outer core.

BRIDGE 2740017 Miller County Swinging Bridge Road

TYPICAL

CONDITIONS:

UPPER	NORTH	SOUTH
U72-U73	6 loose strands in outer core.	11 loose strands in outer core.
U73-U74	7 loose strands in outer core.	9 loose strands in outer core.
U74-U75	6 loose strands in outer core.	8 loose strands in outer core.
U75-U76	6 loose strands in outer core.	7 loose strands in outer core.
U76-U77	6 loose strands in outer core. 1 broken strand at U76.	7 loose strands in outer core.
U77-U78	4 loose strands in outer core.	6 loose strands in outer core.
U78-U79	3 loose strands in outer core.	2 loose strands in outer core.
U79-U80	2 loose strands in outer core.	3 loose strands in outer core.
U80-U81	2 loose strands in outer core.	3 loose strands in outer core.
U81-U82	2 loose strands in outer core.	2 loose strands in outer core. 1 broken strand.
U82-Tower	2 loose strands in outer core. Saddle good.	2 loose strands in outer core. Saddle good.
Tower- Anchor		

BRIDGE
Miller County
Swinging Bridge Road

	10 wires wrapped per cable - Wrapped around Floor beam. General rusting
	and minor to moderate pitting in cables. Minor wear in strands at top flange
TYPICAL	of floor beam (TFFB), except as noted. Section loss in top of cables from
CONDITIONS:	general pitting.

HANGER	NORTH	SOUTH
	1 strand broken - top. Cable well twisted	
H1	tight.	Cable well twisted - tight.
	1 broken strand - bottom. Slight wear to	
	cable at floor beam. Cable unwrapping -	1 broken strand - bottom. Cable well
H2	loose.	twisted - tight.
		4 broken strands - bottom; 1 broken strand
	2 broken strands - bottom. Various	top. No wear in cables but cables are
Н3	untwisting of cable - loose.	loose.
	4 broken strands - bottom. 2 broken	
	strands - top. 50% section loss in 1 strand	Cables were replaced with new strands in
H4	(TFFB). Various untwisting of cable - tight.	past. No wear. Cable twisted but loose.
		1 broken strand - bottom. 50% section loss
H5	Cable tight.	in 2 strands (TFFB). Cable is taught.
	No wear in cable strands. Cable is	50% section loss in 1 strand (TFFB). Cable is
H6	untwisted - loose.	taught.
	1 broken strand - bottom. 50% section loss	
	in 1 strand (TFFB). Cable is untwisting - but	
H7	taught.	2 broken strands - bottom. Cable is taught.
	1 harden	FGG/ anation loss in 1 atrond /TEED). Cable is
110	1 broken strand - bottom. 75% section loss	50% section loss in 1 strand (TFFB). Cable is
H8	in 1 strand (TFFB). Cable is tight.	untwisted but tight.
	Saddle wrap around bottom of floor beam	
110	has shifted. 50% section loss in 1 strand.	FOOV and the allowing 2 atmospherical controls
Н9	Cable is loose.	50% section loss in 3 strands. Cable is loose
	50% section loss in 3 strands Cable is	50% section loss in 3 strands. Cable is
H10	untwisting but taught.	untwisting and loose.
LITO	untwisting but taught.	untwisting and loose.
H11	50% section loss in 3 strands Cable is loose.	Cable is untwisting and taught.
		50% section loss in 3 strands. Various parts
H12	Minor wear in 3 strands. Cable is tight.	of cable untwisting. Cable is loose.

10 wires wrapped per cable - Wrapped around Floor beam. General rusting and minor to moderate pitting in cables. Minor wear in strands at top flange of floor beam (TFFB), except as noted. Section loss in top of cables from general pitting.

HANGER	NORTH	SOUTH
		50% section loss in 2 strands (TFFB). Cable
H13	 50% section loss in 3 strands. Cable is loose.	
1113	4 broken strands - bottom. 50% section	twisted and taught.
	loss in 1 strand (TFFB). Cable is untwisting	
H14	and loose.	Cable untwisted and loose.
	3 broken strands - bottom; 1 broken strand	
	top. 75% section loss in 2 strands (TFFB).	1 broken strand. 50% section loss in 1
H15	Cable is untwisting and loose.	strand (TFFB). Cable is taught.
	50% section loss in 3 strands (TFFB). Cable	1 broken strand. 50% section loss in 2
H16	is semi-twisted, but loose.	strands (TFFB). Cable is taught.
		CONTRACTOR OF THE PARTY COLUMN
1147	50% section loss in 2 strands (TFFB). Cable	50% section loss in 4 strands (TFFB). Cable
H17	mainly untwisted and loose.	is loose.
	25% section loss in 2 strands (TFFB). Cable	25% section loss in 4 strands (TFFB). Cable
H18	is semi-twisted and taught.	is loose.
1110	is semi-twisted and taught.	15 1005€.
	50% section loss in 3 strands (TFFB). Cable	50% section loss in 3 strands (TFFB). Cable
H19	is untwisted but taught.	is twisted and loose.
	50% section loss in 2 strands (TFFB). Cable	75% section loss in 2 strands (TFFB). Cable
H20	is untwisted but taught.	is semi-twisted and taught.
	75% section loss in 2 strands (TFFB). Cable	50% section loss in 2 strands (TFFB). Cable
H21	is untwisting, but tight.	is twisted and taught.
	75% section loss in 1 strand + 25% section	2/3 up cable - pitting (15% section loss).
	loss in 1 strand (TFFB). Cable untwisting	75% section loss in 4 strands - bottom
H22	but tight.	(TFFB). Cable semi-twisted and taught.
	20% section loss in general in top of cables. 75% section loss in 2 strands + 25% section loss in 1	
	section loss in 2 strands + 25% section loss in 1 strand - bottom (TFFB). Cable untwisting loose	Rehabbed in past. Mainly cable is untwisted
H23	but tight.	and loose.
	20% section loss in top of cables. 75% section	50% section loss in 3 strands (TFFB).
	loss in 1 strand + 25% section loss in 2 strands	Heavier pitting at 2/3 point up the cable.
H24	(TFFB).	Cable untwisted and loose.

TYPICAL CONDITIONS:

10 wires wrapped per cable - Wrapped around Floor beam. General rusting and minor to moderate pitting in cables. Minor wear in strands at top flange of floor beam (TFFB), except as noted. Section loss in top of cables from general pitting.

HANGER	NORTH	SOUTH
	20% general section loss in upper hangers.	20% general section loss in upper 1/3 of
	50% section loss in 3 strands (TFFB). Cable	hanger assembly. 15% section loss in 3
H25	is tight.	strands (TFFB). Cable tight.
	20% general section loss in upper hangers. 50%	20% general section loss in upper 1/3 of
	section loss in 1 strand + 25% section loss in 2	hanger assembly. 25% section loss in 4
H26	strands. (TFFB). Cable is taught.	strands (TFFB). Cable is loose.
		1 has been stored button 200/ assessed as ation
	200/ costion loss in upper hongors 250/ costion	1 broken strand - bottom. 20% general section loss in top of hanger cables. 10% section loss in
H27	20% section loss in upper hangers. 25% section loss in 2 strands (TFFB). Cable is tight.	1 strand (TFFB). Cable loose. Out of alignment.
1127	20% section loss in upper hangers. 50%	20% general section loss in top of hanger
	section loss in 2 strands + 25% section loss	assembly. 25% section loss in 2 strands
H28	in 1 strand (TFFB). Cable is loose.	(TFFB). Cable is tight.
1120	15% general section loss in upper hangers.	20% general section loss in top of hanger
	50% section loss in 4 strands (TFFB). Cable	assembly. 50% section loss in 4 strands
H29	is tight.	(TFFB). Cable is taught.
1125	20% general section loss in upper hangers.	2 broken strands - bottom. 20% general
	50% section loss in 3 strands (TFFB). Cable	section loss upper cables. 15% section loss
H30	is tight.	in 3 strands (TFFB). Cable is loose.
	20% general section loss in upper hangers	1 broken strand - top. 20% general section
	(pitting). 50% section loss in 2 strands	loss in upper cables. 50% section loss in 4
H31	(TFFB). Cable is taught.	strands (TFFB). Cables tight.
	20% general section loss in upper hangers	20% general section loss in upper cables.
	(pitting). 25% section loss in 4 strands	25% section loss in 2 cables (TFFB). Cables
H32	(TFFB). Cable is tight.	are tight.
	1 broken strand - bottom. 20% general section	1 broken strand top. 20% general section
	loss in upper hangers. 50% section loss in 2	loss in upper cables. 50% section loss in 3
H33	strands (TFFB). Cable is tight.	strands (TFFB). Cables tight.
	20% general section loss in upper hangers.	20% general section loss in upper cables.
	25% section in 2 strands (TFFB). Cable is	50% section loss in 4 strands (TFFB). Cables
H34	tight.	tight.
	20% general section loss in upper hangers. 75%	15% general section loss in upper hangers. 50%
	section loss in 1 strand + 50% section loss in	section loss in 3 strands + 25% section loss in 3
H35	strands (TFFB). Cables tight.	strands. Cables tight.
	15% general section loss in upper hangers. 75%	1 broken strand in top. 20% general section loss
	section loss in 2 strands + 25% section loss in 1	in upper hangers. 25% section loss in 3 strands
H36	strand (TFFB). Cable is tight.	(TFFB). Cables tight.

	10 wires wrapped per cable - Wrapped around Floor beam. General rusting
	and minor to moderate pitting in cables. Minor wear in strands at top
TYPICAL	flange of floor beam (TFFB), except as noted. Section loss in top of cables
CONDITIONS:	from general pitting.

HANGER	NORTH	SOUTH
	20% general section loss in upper hangers	1 broken strand bottom. 20% section loss
	(pitting). 50% section loss in 4 strands (TFFB).	in upper hangers. 75% section loss in 4
H37	Cable is tight.	strands (TFFB).
	20% general section loss in upper hangers.	
	75% section loss in 2 strands (TFFB). Cable	20% section loss in upper hangers. 25%
H38	tight, but not twisted.	section loss in 2 strands (TFFB). Cable tight
	3.4	
	1 broken strand - bottom. 20% general section	1 broken strand bottom. 20% section loss
	loss in upper hangers. 50% section loss in 3	in upper hangers. 50% section loss in 3
H39	strands (TFFB). Cable tight but untwisted.	strands (TFFB). Cable tight.
	20% general section loss in upper hangers.	20% section loss in upper hangers. 75%
	75% section loss in 3 strands (TFFB). Cable	section loss in 2 strands +25% section loss
H40	tight but untwisted.	in 3 strands (TFFB). Cable tight.
		1 broken strand bottom. 20% section loss in
	20% general section loss in upper hangers.	upper hangers. 75% section loss in 2 strands +
	50% section loss in 5 strands (TFFB). Cable	25% section loss in 2 strands (TFFB). Cable is
H41	is tight.	tight.
		3 harden stand de le stere 450/ es stien
	1 broken strand -bottom. 20% general section	2 broken strands - bottom. 15% section
	loss in upper hangers. 50% section loss in 2	loss in upper hangers. 25% section loss in
H42	strands (TFFB). Cable tight, but untwisted.	4 strands (TFFB). Cable tight.
	2 broken strands - bottom. 20% general section	
	loss in upper hangers. 50% section loss in 4	upper hangers. 50% section loss in 3 strands
H43	strands (TFFB). Cable is tight.	(TFFB). Cable is tight, untwisted.
	20% general section loss in upper hangers.	
	50% section loss in 3 strands (TFFB). Cable	20% section loss in upper hangers. 25%
H44	is tight.	section loss in 3 strands (TFFB). Cable tight
	20% general section loss in upper hangers.	2 broken strands bottom. 15% section los
	50% section loss in 4 strands (TFFB). Cable	in upper hangers. 50% section loss in 3
H45	is tight.	strands (TFFB). Cable is tight.
	2 broken strands -bottom. 20% general section	1 broken strand bottom. 10% section loss
	loss in upper hangers. 50% section loss in 3	in upper hangers. 25% section loss in 4
H46	strands (TFFB). Cable is tight.	strands (TFFB). Cable is tight.
	1 broken strand-bottom + 1 broken strand -	
	top. 20% general section loss in upper hangers.	4 broken strands bottom + 1 broken -top. 15%
	25% section loss in 5 strands (TFFB). Cable	section loss in upper hangers. 75% section loss
H47	tight, but untwisted.	in 2 strands (TFFB). Cable is tight.
	4 broken strands -bottom + 1 broken strand	1 broken strand bottom, 15% section loss
	top. 20% general section loss in upper hangers.	
1140	25% section loss in 4 strands (TFFB). Cable is	in upper hangers. 50% section loss in 1
H48	tight.	strand (TFFB).

TYPICAL CONDITIONS:

10 wires wrapped per cable - Wrapped around Floor beam. General rusting and minor to moderate pitting in cables. Minor wear in strands at top flange of floor beam (TFFB), except as noted. Section loss in top of cables from general pitting.

HANGER	NORTH	SOUTH
H49	1 broken strand-top. 20% general section loss in upper hangers. 75% section loss in 3 strands + 25% section loss in 2 strands (TFFB). Cable tight, untwisted.	10% general section loss in upper hangers. 50% section loss in 2 strands (TFFB). Cable tight, untwisted.
H50	20% general section loss in upper hangers. 25% section loss in 6 strands (TFFB). Cable tight, untwisted.	1 broken strand top and bottom. 10% general section loss in upper hangers. 50% section loss in 2 strands (TFFB). Cable tight, untwisted.
H51	1 broken strand-bottom. 20% general section loss in upper hangers. 25% section loss in 3 strands (TFFB). Cable tight, untwisted.	3 broken strands - bottom. 10% general section loss in upper hangers. 75% section loss in 3 strands (TFFB). Cable tight.
H52	4 broken strand-bottom. 20% general section loss in upper hangers. 25% section loss in 3 strands (TFFB). Cable tight.	1 broken strand - bottom. 15% general section loss in upper hangers. 25% section loss in 3 strands (TFFB). Cable tight.
H53	20% general section loss in upper hangers. 25% section loss in 3 strands (TFFB). Cable tight.	1 broken strand - bottom. 10% general section loss in upper hangers. 75% section loss in 2 strands (TFFB). Cable tight.
H54	1 broken strand-bottom. 20% general section loss in upper hangers. 25% section loss in 4 strands (TFFB). Cable tight.	2 broken strands - bottom. 15% general section loss in upper hangers. 25% section loss in 4 strands (TFFB). Cable tight.
Н55	1 broken strand-bottom. 20% general section loss in upper hangers. 25% section loss in 2 strands (TFFB). Cable tight.	1 broken strand - bottom. 15% general section loss in upper hangers. 25% section loss in 3 strands (TFFB). Cable tight, 3" out of vertical.
Н56	1 broken strand-bottom. 20% general section loss in upper hangers. 25% section loss in 3 strands (TFFB). Cable tight.	1 broken strand - bottom. 15% general section loss in upper hangers. 25% section loss in 4 strands (TFFB). Cable tight.
H57	20% general section loss in upper hangers. 50% section loss in 4 strands (TFFB). Cable tight.	1 broken strand - bottom. 20% general section loss in upper hangers. 25% section loss in 4 strands (TFFB). Cable tight.
H58	1 broken strand-bottom. 20% general section loss in upper hangers. 50% section loss in 3 strands (TFFB). Cable tight.	20% general section loss in upper hangers. 25% section loss in 4 strands (TFFB). Cable tight.
H59	20% general section loss in upper hangers. 50% section loss in 5 strands (TFFB). Cable tight.	20% general section loss in upper hangers. 50% section loss in 3 strands (TFFB). Cable tight, untwisted.
H60	1 broken strand-bottom. 25% general section loss in upper hangers. 25% section loss in 2 strands (TFFB). Cable tight, twisted.	1 broken strand - bottom. 20% general section loss in upper hangers. 50% section loss in 1 strands (TFFB). Cable tight.

10 wires wrapped per cable - Wrapped around Floor beam. General ru		
	and minor to moderate pitting in cables. Minor wear in strands at top flange	
TYPICAL	of floor beam (TFFB), except as noted. Section loss in top of cables from	
CONDITIONS:	general pitting.	

HANGER	NORTH	SOUTH
	20% general section loss in upper hangers.	20% section loss in upper hangers. 50%
	75% section loss in 3 strands (TFFB). Cable	section loss in 3 strands (TFFB). Cable is
H61	is tight, untwisted.	tight.
	25% general section loss in upper hangers.	20% section loss in upper hangers. 25%
	25% section loss in 3 strands (TFFB). Cable	section loss in 3 strands (TFFB). Cable is
H62	is tight, untwisted.	tight - 3" out of vertical.
	25% general section loss in upper hangers.	20% section loss in upper hangers. 50%
	25% section loss in 3 strands (TFFB). Cable	section loss in 3 strands (TFFB). Cable is
H63	is tight.	tight -4" out of vertical.
	20% general section loss in upper hangers.	1 broken strand - bottom. 20% section los
	25% section loss in 3 strands (TFFB). Cable	in upper hangers. 75% section loss in 2
	is taught, untwisted.	strands (TFFB). Cable is tight - 3" out of
	1 broken strand - bottom. 20% general section	20% section loss in upper hangers. 50%
	loss in upper hangers. 75% section loss in 2	section loss in 2 strands (TFFB). Cable is
H65	strands (TFFB). Cable is taught.	tight - 2" out of vertical.
	1 broken strand - bottom. 20% general section	20% section loss in upper hangers. 50%
	loss in upper hangers. 75% section loss in 3	section loss in 3 strands (TFFB). Cable is
H66	strands (TFFB). Cable is tight.	tight - 2" out of vertical.
	20% general section loss in upper hangers.	1 broken strand - bottom. 25% section los
	50% section loss in 4 strands (TFFB). Cable	in upper hangers. 75% section loss in 2
H67	is tight.	strands (TFFB). Cable is tight.
	20% general section loss in upper hangers.	20% section loss in upper hangers. 50%
	50% section loss in 2 strands (TFFB). Cable	section loss in 3 strands (TFFB). Cable is
H68	is loose.	loose, untwisted.
	20% general section loss in upper hangers. 25%	25% section loss in upper hangers. 25%
	section loss in 1 strand (TFFB). Cable is taught,	section loss in 5 strands (TFFB). Cable is
H69	but out of vertical.	tight.
	20% general section loss in upper hangers.	20% section loss in upper hangers. 50%
	25% section loss in 2 strands (TFFB). Cable	section loss in 1 strand (TFFB). Cable is
H70	is tight.	loose. Out of vertical.
		25% section loss in upper hangers. 25%
	25% general section loss in upper hangers.	section loss in 2 strands (TFFB). Cable is
	Cable is loose, untwisted.	taught, untwisted.
		1 broken strand - top and bottom. 25% section
	20%	loss in upper hangers. 25% section loss in 1
11770	20% general section loss in upper hangers.	strand (TFFB). Cable is taught, but way out of
H72	Cable is loose.	alignment.


	10 wires wrapped per cable - Wrapped around Floor beam. General rusting	
	and minor to moderate pitting in cables. Minor wear in strands at top	
TYPICAL	flange of floor beam (TFFB), except as noted. Section loss in top of cables	
CONDITIONS:	from general pitting.	

HANGER	NORTH	SOUTH
	20% general section loss in upper hangers.	1 broken strand - bottom. 20% section
	25% section loss in 3 strands (TFFB). Cable	loss in upper hangers. 25 % section loss in
H73	is tight.	2 strands (TFFB). Cable is tight.
	20% general section loss in upper hangers.	15% section loss in upper hangers. 75 %
	25% section loss in 1 strand (TFFB). Cable	section loss in 1 strand + 50% section loss
H74	is loose.	in 2 strands (TFFB). Cable is loose.
	15% general section loss in upper hangers.	15% section loss in upper hangers. 10 %
	25% section loss in 1 strand (TFFB). Cable	section loss in 2 strands (TFFB). Cable is
H75	is loose.	loose.
	15% general section loss in upper hangers.	20% section loss in upper hangers. 25 %
	50% section loss in 1 strand (TFFB). Cable	section loss in 2 strands (TFFB). Cable is
H76	is taught.	taught.
	20% general section loss in upper hangers.	1 broken strand - bottom. 15% section
	25% section loss in 2 strands (TFFB). Cable	loss in upper hangers. 25 % section loss in
H77	is taught.	2 strands (TFFB). Cable is tight.
		20% section loss in upper hangers. 10%
	20% general section loss in upper hangers.	section loss in 2 strands (TFFB). Cable is
H78	Cable is loose.	loose.
	20% general section loss in upper hangers.	15% section loss in upper hangers. 25 %
	10% section loss in 1 strand (TFFB). Cable	section loss in 2 strands (TFFB). Cable is
H79	is loose.	taught. Out of vertical.
	15% general section loss in upper hangers.	20% section loss in upper hangers. 10%
	25% section loss in 1 strand (TFFB). Cable	section loss in 2 strands (TFFB). Cable is
H80	is loose.	loose. Out of vertical.
	15% general section loss in upper hangers.	2 broken strands - bottom. 20% section
	10% section loss in 2 strands (TFFB). Cable	loss in upper hangers. 10 % section loss in
H81	is loose.	1 strand (TFFB). Cable is loose. Out of
	1 strand is broken -bottom. 10% general	
	section loss in upper hangers. 25% section	15% section loss in upper hangers. Cable
H82	loss in 1 strand (TFFB). Cable is loose.	is loose. Out of vertical.

FRACTURE CRITICAL INSPECTION REPORT **BRIDGE 2740017** MILLER COUNTY, MISSOURI

INSPECTION PHOTOGRAPHS

GENERAL VIEWS



- ☐ 100 SOUTH 54TH STREET
- ☐ 3523 MAIN STREET

- P.O. BOX 709 QUINCY, IL 62306
- P.O. BOX 817 KEOKUK, IA 52632
- ☐ 801 BROADWAY SUITE 248 P.O. BOX 190 HANNIBAL, MO 63401
- PHONE 217/223-4605 FAX 217/223-1546
- PHONE 319/524-8730 FAX 217/223-1546
- PHONE 573/406-0541 FAX 217/223-1546

GENERAL VIEWS: (cont.)




Developing Partnerships

Creating Innovative Solutions

Delivering Proven Results

GENERAL VIEWS: (cont.)







Developing Partnerships

Creating Innovative Solutions

Delivering Proven Results


GENERAL VIEWS: (cont.)






Developing Partnerships
Creating Innovative Solutions Delivering Proven Results

MAIN SUSPENSION CABLES









Developing Partnerships


Creating Innovative Solutions

Delivering Proven Results

MAIN SUSPENSION CABLES: (cont.)








Developing Partnerships

Creating Innovative Solutions

Delivering Proven Results

MAIN SUSPENSION CABLES: (cont.)





Developing Partnerships

Creating Innovative Solutions

Delivering Proven Results


MAIN SUSPENSION CABLES: (cont.) MILLER COUNT MAIN CABLE U 08-07-18 General main c MILLER COUNTY BR. NO. 2740017 08-07-1 MAIN CABLE U13-U14 North General main cable view near East Tower MILLER COUNTY BR. NO. 2740017 08-07-18 MAIN CABLE U13-U14 North Seneral main cable view near East [

MAIN SUSPENSION CABLES: (cont.)





MAIN SUSPENSION CABLES: (cont.)



HANGER CABLES



Developing Partnerships Creating Innovative Solutions Delivering Proven Results

HANGER CABLES: (cont.) MILLER COUNTY BR. NO. 2740017 08-07-18 HANGER 9 North Hanger cable shifted off saddle. 50% SL to 1 cable.


MILLE CONTROL AND THE CONTROL OF CONTROL OF


Developing Partnerships

Creating Innovative Solutions

Delivering Proven Results


HANGER CABLES: (cont.)





Developing Partnerships

Creating Innovative Solutions Delivering Proven Results



Developing Partnerships

Creating Innovative Solutions

Delivering Proven Results

SUSPENSION TOWERS



Developing Partnerships

Creating Innovative Solutions

Delivering Proven Results


SUSPENSION TOWERS: (cont.)



Developing Partnerships

Creating Innovative Solutions Delivering Proven Results


FLOOR BEAMS AND STRINGERS



Developing Partnerships Creating Innovative Solutions Delivering Proven Results

FLOOR BEAMS AND STRINGERS: (cont.)





Developing Partnerships

Creating Innovative Solutions

Delivering Proven Results